

Damixa Lyra, Primola and Space, 1-handle kitchen mixer

Holder/Issued to

FM Mattsson Mora Group Danmark ApS

Østbirkvej 2, 5240 Odense NØ, Denmark.

Organisation number: 56416218.

Tel: +45 63102210, fax: +45 63102209

E-mail: danmark@fmm-mora.com Web: www.damixa.com

Product description

Damixa Lyra, Primola and Space 1-handle mixer for kitchen, with or without shut off valve for dishwasher. Swivels are limited to 120°. Mixers are supplied with flexible connection hoses that are covered by Swedish technical approval and have connection G 3/8" or Ø 10 mm.

Intended use

Single handle mixer intended for drinking water.

Trade name

1-handle kitchen mixer,

Damixa Lyra with connection Ø 10 mm, Damixa no. 510000000.

Damixa Lyra with connection G 3/8", Damixa no. 510000038.

Damixa Lyra with dishwasher shut, connection Ø 10 mm, Damixa no. 510010000.

Damixa Lyra with dishwasher shut, connection G 3/8", Damixa no. 510010038.

Damixa Primola with dishwasher shut off, connection Ø 10 mm, Damixa no. 510710000.

Damixa Primola with dishwasher shut off, connection G 3/8", Damixa no. 510710038.

Damixa Primola with connection Ø 10 mm, Damixa no. 510780000.

Damixa Primola with connection G 3/8", Damixa no. 510780038.

Damixa Space with connection Ø 10 mm, Damixa no. 100700000.

Damixa Space with connection G 3/8", Damixa no. 100700038.

Damixa Space with dishwasher shut off, connection Ø 10 mm, Damixa no. 100710000.

Damixa Space with dishwasher shut off, connection G 3/8", Damixa no. 100710038.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations*	6:62,	1 st sentence and 2 nd paragraph and general recommendation
Tap water flow	6:623	1 st sentence
Design	6:625,	1 st and 4 th paragraph

Type approval SC0706-17 | 2018-01-09

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-501 15 Borås, Sweden

Phone: +46 10-516 50 00

certifiering@ri.se | www.ri.se

2017-07-05



7P06373

(7P03019)



Approval continue

*Mixers comply with Boverket's (the National Board of Housing, Building and Planning) updated threshold value for max. amount of dissolved lead as described in BBR 21, 2014-06-17.

Associated documents

Installation instruction Damixa, version 02.11 - 20065.00.

User instruction Damixa, version 12.06 - 12676.00.

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control agreement: 210-17-0103. Inspection body: RISE Research Institutes of Sweden AB.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

Manufacturing place

Production control includes the following place:

FM Mattsson Mora Group Denmark ApS Odense and production site 912350.

Marking

The products are to be marked at the factory.

The marking consists of a text on every product and packing and includes:

Distributor*
Boverket's registered trade mark
Certification body and accreditation number
Type approval number
Product type designation
Consecutive manufacture year and month*
Inspection body

Damixa

RISE Certifying 1002
SC0706-17
trade name
yy.mm
RISE

*text on mixer

Basis for judgement/approval

Report 7381279-01 from LGA, Germany.

Report 6P09796-01 from SP Technical Research Institute of Sweden.

Report VTT-S-00142-15 from VTT, Finland.

Comments

Mixers are approved in accordance with SS-EN 817.

Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

This approval supersedes the previous approval with the same number dated 2017-06-19.

Type approval SC0706-17 | 2018-01-09

RISE Research Institutes of Sweden AB | Certification

Validity

Valid through 2022-06-18.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Ingvar Pettersson

Marcus Tillman

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.